



**NOTES:**

1. TAPS MADE TO THE V-BIO POLYETHYLENE ENCASED PIPE MUST BE MADE IN STRICT CONFORMANCE TO THE MANUFACTURERS INSTALLATION REQUIREMENTS. ENCASEMENT INTEGRITY MUST NOT BE BREACHED.
2. ALL PIPES, FITTINGS, AND FIXTURES IN CONTACT WITH POTABLE WATER SHALL BE LEAD FREE PER THE REDUCTION OF LEAD IN DRINKING WATER ACT AND NSF / ANSI STANDARD 61 (NSF-61). LEAD FREE IS DEFINED AS CONTAINING NOT MORE THAN A WEIGHTED AVERAGE OF 0.25 PERCENT LEAD WHEN USED WITH RESPECT TO THE WETTED SURFACES OF PIPES, PIPE FITTINGS, PLUMBING FITTINGS, AND FIXTURES.
3. ALL MATERIALS FURNISHED AND INSTALLED MUST COMPLY WITH THE PENNSYLVANIA STEEL PRODUCTS PROCUREMENT ACT.
4. ANY MODIFICATION MUST BE APPROVED BY THE EWW ENGINEERING DEPARTMENT IN ADVANCE.

CORPORATION STOP (BALL VALVE), MUELLER MODEL # B-25000N OR APPROVED EQUAL. SHALL BE DIRECT TAPPED INTO THE MAIN WITH A MINIMUM OF 2 THREADS. A MJ TAPPED TEE, TYLER UNION MODEL # C110 OR APPROVED EQUAL, MAY BE USED IF MAIN THICKNESS DOES NOT ALLOW FOR 2 THREADS. SERVICE SADDLES ARE NOT TO BE USED.

ANSI/AWWA C151/A21.51 CLASS 52 DUCTILE IRON WATER MAIN (DOUBLE CEMENT LINED WITH ASPHALTIC COATING) IN V-BIO POLYETHYLENE ENCASEMENT

(NOT TO SCALE)

DRAWN BY: CE	APPROVED BY: CP
DATE: JAN 2018	EWW - CD - 001

**WATER SERVICE TAP (3/4" & 1")**

**ERIE WATER WORKS**  
 240 West 12th Street  
 Erie, PA 16501  
 engineering@eriewaterworks.org

