

NOTES:

1. TAPS MADE TO THE V-BIO POLYETHYLENE ENCASED PIPE MUST BE MADE IN STRICT CONFORMANCE TO THE MANUFACTURERS INSTALLATION REQUIREMENTS. ENCASUREMENT INTEGRITY MUST NOT BE BREACHED.
2. ALL PIPES, FITTINGS, AND FIXTURES IN CONTACT WITH POTABLE WATER SHALL BE LEAD FREE PER THE REDUCTION OF LEAD IN DRINKING WATER ACT AND NSF/ANSI STANDARD 61 (NSF-61). LEAD FREE IS DEFINED AS CONTAINING NOT MORE THAN A WEIGHTED AVERAGE OF 0.25 PERCENT LEAD WHEN USED WITH RESPECT TO THE WETTED SURFACES OF PIPES, PIPE FITTINGS, PLUMBING FITTINGS AND FIXTURES.
3. ALL MATERIALS FURNISHED AND INSTALLED MUST COMPLY WITH THE PENNSYLVANIA STEEL PRODUCTS PROCUREMENT ACT.
4. ANY MODIFICATION MUST BE APPROVED BY THE EWW ENGINEERING DEPARTMENT IN ADVANCE.

BLOW OFF SAMPLE STATION, SAFETY-GUARD 2" SAMPLE STATION MODEL #SGBSS-19 WITH GREEN COLORED COVER. UNIT SHALL HAVE A 5' MINIMUM BURY DEPTH AND MUST BE SELF DRAINING.

DISCHARGE OF ELBOW SHALL BE FEMALE PIPE THREAD.

#57 COARSE AGGREGATE 6" DEEP AND 6" WIDE AROUND PERIMETER OF UNIT

DRY WELL TO BE LINED WITH 8-MIL POLYETHYLENE ON TOP AND ALL SIDES EXCEPT THE BOTTOM OF THE WELL

#57 COARSE AGGREGATE MINIMUM 1 CUBIC YARD

5' MINIMUM

TWO-PIECE CAST IRON SCREW TYPE 6850 SERIES VALVE BOX WITH 5 1/4" DROP LID. LID SHALL HAVE THE WORD "WATER" FORGED INTO CASTING. EWW VALVE BOXES MUST BE PRODUCED IN ACCORDANCE WITH AND MEET PROVISIONS OF MOST RECENT ASTM A-438, ASTM A-48, AWWA C110/A21, AND AWWA C110/A21 4-90 STANDARDS. TYLER MODEL (562-S, 564-S, OR 664-S) BOX OR EQUAL.

CORPORATION STOP (BALL VALVE), MUELLER MODEL # B-25000N OR APPROVED EQUAL. SHALL BE DIRECT TAPPED INTO THE MAIN WITH A MINIMUM OF 2 THREADS. A MJ TAPPED TEE, TYLER UNION MODEL # C110 OR APPROVED EQUAL, MAY BE USED IF MAIN THICKNESS DOES NOT ALLOW FOR 2 THREADS. SERVICE SADDLES ARE NOT TO BE USED.

2" TYPE K SOFT COPPER. ABSOLUTELY NO SPLICES / FITTINGS ALLOWED.

ANSI/AWWA C151/A21.51 CLASS 52 DUCTILE IRON WATER MAIN (DOUBLE CEMENT LINED WITH ASPHALTIC COATING) IN V-BIO POLYETHYLENE ENCASUREMENT

EWV CURB STOP (1/4- TURN BALL VALVE), MUELLER MODEL # B-25204N OR APPROVED EQUAL.

2'x2'x1' COMPACTED PENNDOT #2A COARSE AGGREGATE.

TAP SHALL BE SUPPORTED TO EDGE OF TRENCH WITH COMPACTED PENNDOT #2A COARSE AGGREGATE.

(NOT TO SCALE)

DRAWN BY: CE	APPROVED BY: CP
DATE: JAN 2018	EWV - CD - 003

# BLOW OFF SAMPLING STATION

**ERIE WATER WORKS**  
 240 West 12th Street  
 Erie, PA 16501  
 engineering@eriewaterworks.org

