


NOTE:

1. ANY MODIFICATION MUST BE APPROVED BY THE EWW ENGINEERING DEPARTMENT IN ADVANCE.

FLAT-BOTTOM TRENCH (UNDISTURBED EARTH) DIG HOLES FOR PLACEMENT OF BELLS AT EACH JOINT IN ACCORDANCE WITH AWWA C600. A CONTINUOUS AND UNIFORM BEDDING AT THE TRENCH BOTTOM MUST BE PROVIDED PER PA DEPARTMENT OF ENVIRONMENTAL PROTECTION (DEP) REQUIREMENTS.



DRAWN BY: PH

APPROVED BY: CP

DATE: OCT 2010

NOT TO SCALE

WATER MAIN TRENCH DETAIL - UNIMPROVED SURFACE

ERIE WATER WORKS
240 West 12th Street
Erie, PA 16501

