

**ERIE CITY WATER AUTHORITY  
2009 (2 samples)  
VOLATILE ORGANIC COMPOUNDS (VOCs)**

	Erie City Water Authority (mg/l)	minimum detection limit (mg/l)	maximum contamination level (mg/l)
<b>Benzene</b>	<0.0005	0.0005	0.005
<b>Carbon Tetrachloride</b>	<0.0005	0.0005	0.005
<b>Monochlorobenzene</b>	<0.0005	0.0005	0.1
<b>1,2-Dichloroethane</b>	<0.0005	0.0005	0.005
<b>ortho-Dichlorobenzene</b>	<0.0005	0.0005	0.6
<b>para-Dichlorobenzene</b>	<0.0005	0.0005	0.075
<b>1,1-Dichloroethene</b>	<0.0005	0.0005	0.007
<b>cis-1,2-Dichloroethene</b>	<0.0005	0.0005	0.07
<b>trans-1,2-Dichloroethene</b>	<0.0005	0.0005	0.1
<b>Dichloromethane</b>	<0.0005	0.0005	0.005
<b>1,2-Dichloropropane</b>	<0.0005	0.0005	0.005
<b>Ethylbenzene</b>	<0.0005	0.0005	0.7
<b>Styrene</b>	<0.0005	0.0005	0.1
<b>Tetrachloroethene</b>	<0.0005	0.0005	0.005
<b>Toluene</b>	<0.0005	0.0005	1.0
<b>1,1,1-Trichloroethane</b>	<0.0005	0.0005	0.2
<b>1,1,2-Trichloroethane</b>	<0.0005	0.0005	0.005
<b>Trichloroethylene</b>	<0.0005	0.0005	0.005
<b>Xylenes</b>	<0.0015	0.0015	10.
<b>1,2,4--Trichlorobenzen</b>	<0.0005	0.0005	0.007
<b>Vinyl Chloride</b>	<0.0005	0.0005	0.002

< Read as "less than" - indicates a result of less than the detection limit of the procedure.