

## Erie Water Works Effluent

2020

### Volatile Organic Compounds (VOCs)

	Erie Water Works Average* ( $\mu\text{g/L}$ ) or ppb	Minimum Detection Limit ( $\mu\text{g/L}$ ) or ppb	Maximum Containment Level ( $\mu\text{g/L}$ ) or ppb
Benzene	< 0.5	0.5	5
Carbon Tetrachloride	< 0.5	0.5	5
Chlorobenzene	< 0.5	0.5	100
1,2-Dichlorobenzene	< 0.5	0.5	600
1,4-Dichlorobenzene	< 0.5	0.5	75
1,2-Dichloroethane	< 0.5	0.5	5
1,1-Dichloroethene	< 0.5	0.5	7
cis-1,2-Dichloroethene	< 0.5	0.5	70
trans-1,2-Dichloroethene	< 0.5	0.5	100
Dichloromethane	< 0.5	0.5	5
1,2-Dichloropropane	< 0.5	0.5	5
Ethylbenzene	< 0.5	0.5	700
Styrene	< 0.5	0.5	100
Tetrachloroethene	< 0.5	0.5	5
Toluene	< 0.5	0.5	1
1,2,4-Trichlorobenzene	< 0.5	0.5	70
1,1,1-Trichloroethane	< 0.5	0.5	200
1,1,2-Trichloroethane	< 0.5	0.5	5
Trichloroethene	< 0.5	0.5	5
Vinyl chloride	< 0.5	0.5	2
o-Xylenes	< 0.5	0.5	-
m,p- Xylenes	< 0.5	0.5	-
Xylenes, total	< 0.5	0.5	10

< Read as "less than" - indicates a result lower than a detectable level of the procedure.

#### KEY

\* Average Based on 3 Samples